

**DOCUMENT 00 90 00**  
**ADDENDUM**

**ADDENDUM NO. [1]                      Date: February 12, 2018**

**RE:                      EAU CLAIRE AREA SCHOOL DISTRICT  
MEMORIAL HIGH SCHOOL OFFICE & LOBBY EXPANSION  
2225 KEITH ST  
EAU CLAIRE, WISCONSIN 54701  
HSR PROJECT NO. 17003-2**

**FROM:                  HSR Associates, Inc  
100 Milwaukee Street  
La Crosse, WI 54603  
(608) 784-1830**

**To:                      Prospective Bidders**

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated January 2018. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

**CHANGES TO BIDDING REQUIREMENTS AND CONDITIONS OF THE CONTRACT:**

1. Section 00 11 13 ADVERTISEMENT FOR BIDS
  - a. Page 2, Pre-bid Meeting: Change meeting time to from 10:30 to 10:00 a.m. All other information remains the same.

**CHANGES TO SPECIFICATIONS:**

2. Section 10 22 39 FOLDING PANEL PARTITIONS
  - a. Door panel height shall be coordinated with supplier's requirements.
  - b. Delete 2.02, E and F.
  - c. 2.02, H: Delete last sentence.

**CHANGES TO DRAWINGS**

3. Sheet A303 SECTIONS
  - a. 3A303: The lintel shown at the opening into the panel closet reflects a 16 inch deep member. Structural requires only an 8 inch deep lintel. The bottom of new lintel will be 124'-0".
  - b. The height of the pocket beam shall be coordinated with door supplier.

**END OF DOCUMENT 00 90 00**