

**DOCUMENT 00 90 00**  
**ADDENDUM**

**ADDENDUM NO. [5]**                      **Date: May 21, 2018**

**RE:                      WESTERN TECHNICAL COLLEGE**  
**INDOOR SHOOTING RANGE**  
**11177 COUNTY RD A**  
**SPARTA, WI 54656**

**FROM:                HSR Associates, Inc**  
**100 Milwaukee Street**  
**La Crosse, WI 54603**  
**(608) 784-1830**

**To:       Prospective Bidders**

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May 2018. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

**CHANGES TO PREVIOUS ADDENDUM: Addendum 4**

1. Item 2: Door hardware: Delete Item 2. Revision shall be to Addendum 3, Item 4.
  - a. Change Threshold number "S425A96" to "S425A108".
  - b. Change Weatherstrip number "815A9684" to "815A10884".

**CHANGES TO SPECIFICATIONS**

2. SECTION 28 31 00 – FIRE ALARM AND DETECTION.
  - a. Provide expansion of existing fire alarm system.
  - b. All devices and equipment shall be "Notifier", no substitutes.
  - c. Provide an annunciator panel in Vestibule 100.

**CHANGES TO DRAWINGS**

3. Sheet E100 ELECTRICAL REMODEL PLANS
  - a. Plan 3E100: Existing electric service detail: There are (2) Conduits feeding existing site lights from junction box. Contractor shall extend both raceways and wiring to new panel 'DP'.
4. Sheet E500 ELECTRICAL SCHEDULES
  - a. Electric Riser Diagram: Provide 4" conduit from transformer to meter socket in lieu of 5".
  - b. Motor schedule:
    - i. Motor #1 to be 218 MCA in lieu of 3HP.
    - ii. Motors #3 and #4 to be 1/3 HP at 120 volts. Provide 20 amp circuit breakers from panel 'A'.
  - c. Panelboard schedule:
    - i. Panel 'DP': Delete (2) 20 amp 3 pole circuit breakers for circuits DP-8, 10, 12 and DP-7, 9, 11.

**END OF DOCUMENT 00 90 00**