

**DOCUMENT 00 90 00
ADDENDUM**

ADDENDUM NO. [2] Date: June 7, 2018

**RE: WESTERN TECHNICAL COLLEGE
 WELLNESS CENTER RENOVATION
 111 SEVENTH STREET NORTH
 LA CROSSE, WISCONSIN 54601
 HSR PROJECT NO. 18010**

**FROM: HSR Associates, Inc
 100 Milwaukee Street
 La Crosse, WI 54603
 (608) 784-1830**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May 25, 2018. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [3] 8.5X11 pages.

CHANGES TO BIDDING REQUIREMENTS AND CONDITIONS OF THE CONTRACT: NO CHANGES

GENERAL REQUIREMENTS:

1. Prebid Attendance list attached hereto.

CHANGES TO SPECIFICATIONS:

1. Section 09 91 23 INTERIOR PAINTING
 - a. 2.03 A: IPS3 Wood (wood beams and wood base) Stain (ST-1) to be Sherwin Williams Wood Classics Stain, color from full manufacturer line (matching floor). AND Beams – 2 coats Minwax Helmsman Spar Urethane Satin; Base - 3 coats Minwax Helmsman Spar Urethane Satin. Or equal.
2. Section 22 05 23 GENERAL DUTY VALVES
 - a. 2.01 A:
 1. Manufacturers: Only products by Conbraco (Apollo) or Jomar will be acceptable.
3. Section 22 05 29 HANGERS AND SUPPORTS
 - a. 2.01 D:
 1. Where multiple pipes are supported on channels, only pre-insulated pipe clamps will be allowed. Anvil-Strut “Klo-Shure” strut-mounted insulation couplings with strut clamp, or similar product, shall be used. Individual hangers, as specified, are allowed, but insulation must be continuous through the hanger, regardless of fluid or water temperature.

4. Section 22 11 13 FACILITY WATER DISTRIBUTION PIPING

a. 2.04:

1. Delete this section in its entirety. Water hammer suppressors will not be required.

b. 3.06:

2. Delete this section in its entirety. Water hammer suppressors will not be required.

CHANGES TO DRAWINGS

1. Sheet P101 PLUMBING DETAILS, ISOMETRICS, SCHEDULES

a. Refer to the "DRAINS SCHEDULE":

1. The Plumbing Contractor shall provide and install a hair catcher strainer in each of the trench drain outlet flashing drains. Hair catcher shall be a Danco strainer with white metal ring and plastic strainer designed to fit in a 3 inch outlet. (Danco Model 10533 or similar product.)

b. Refer to the "PLUMBING FIXTURES AND TRIM SCHEDULE":

1. Shower "SF-2" shall be supplied with a fixed shower head and a diverter valve, in addition to the hand-held shower, hose, and slide bar, such that the shower may be used as a conventional shower, or may be switched to the hand-held shower, by operation of the diverter handle.

PRIOR APPROVALS

1. SPECIFICATION SECTION 08 71 00 DOOR HARDWARE

1. Mag hold Open; ABH #2100.
2. Strike; HES #1006.

END OF DOCUMENT 00 90 00



ARCHITECTURE
ENGINEERING
INTERIOR DESIGN

HSR 18010	6-6-18	WTC Wellness Pre bid
Daniel Blumer	HSR	dblumer@hsrassociates.com
STEVE KEPROS	M&J	skepros@Market-Johnson.com
DALTON LUNDE	M&J	dlunde@market-johnson.com
Paul Siegman	PJT	paulptelec@acegroup.cc
Paul Amborn	Western	
Bruce Kendall		Kendallb@westerntc.edu
ANDREW WIESER	Wieser	andrew@wieserbrothers.com
Joe Dyer	↓	joed@wieserbrothers.com
DAVID MULLER	Schneider HTG	dave@schneiderheating.com
Kevin Kudrew	B+B Electric	kevink@b-belectricinc.com
Art Herbst	Kish & Sons Electric	art@kishelectric.com
MIKE MALLER	FH	maller@foalerhammer.com