

**DOCUMENT 00 90 00
ADDENDUM**

ADDENDUM NO. [1] Date: October 5, 2018

**RE: PRENTICE SCHOOL DISTRICT
 ADDITION AND REMODELING BID PKG 2
 1025 TOWN ST
 PRENTICE, WI 54556
 HSR PROJECT NO. 18022**

**FROM: HSR Associates, Inc
 100 Milwaukee Street
 La Crosse, WI 54603
 (608) 784-1830**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 9-19-2018. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

CHANGES TO BIDDING REQUIREMENTS AND CONDITIONS OF THE CONTRACT: N/A

GENERAL REQUIREMENTS: N/A

CHANGES TO SPECIFICATIONS: NA

CHANGES TO DRAWINGS

1. Sheet S001 Structural Notes
 - a. System Notes
 - i. *Add at "Backfill"*: Contractor BASE BID shall include appropriate backfill from OFF SITE which is not frozen or otherwise compromised for use in backfilling operations. IF appropriate backfill is found on site that is not frozen or otherwise compromised, and which meets specifications requirements, said fill may be utilized in lieu of offsite fill and credit for unneeded offsite fill shall be given per the UNIT PRICE UP-2 listed at specification Section 01 22 00.

PRIOR APPROVALS: N/A

END OF DOCUMENT 00 90 00