

**DOCUMENT 00 90 00
ADDENDUM**

ADDENDUM NO. [4] Date: October 9, 2018

**RE: GLENWOOD COMMUNITY SCHOOL DISTRICT
ATHLETIC COMPLEX IMPROVEMENTS BID PACKAGE 2
400 SIVERS ROAD
GLENWOOD, IOWA 51534
HSR PROJECT NO. 18005**

**FROM: HSR Associates, Inc
100 Milwaukee Street
La Crosse, WI 54603
(608) 784-1830**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated September 2018. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

CHANGES TO PRIOR ADDENDA:

1. Addendum 2, Item 11:
 - a. Sheet S302R DETAILS
 - i. In detail 1/S302R the required continuous longitudinal reinforcing for the retaining wall footings are as follows:
 - 1). Type I wall: 3-#5 CONT T&B
 - 2). Type II wall: 4-#5 CONT T&B
 - ii. In detail 2/S302R, the required continuous longitudinal reinforcing for the retaining wall footings are as follows:
 - 1). Type III wall: 3-#5 CONT T&B
 - 2). Type IV wall: 4-#5 CONT T&B

END OF DOCUMENT 00 90 00