

DOCUMENT 00 90 00

ADDENDUM

ADDENDUM NO. [1]

Date: October 23, 2018

**RE: HOUSING AUTHORITY OF THE CITY OF LA CROSSE
PING MANOR SUNROOM WINDOW REPLACEMENT
LA CROSSE, WISCONSIN
HSR PROJECT NO. 18051**

**FROM: HOUSING AUTHORITY OF THE CITY OF LA CROSSE
1307 BADGER STREET
P.O. BOX 1053
LA CROSSE, WISCONSIN 54602-1053**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated October 2018. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

CHANGES TO SPECIFICATIONS:

1. Section 08 43 13 ALUMINUM FRAMED STOREFRONT
 - a. 2.02, A, 4: Delete "Black". Color shall match other frames on the building that are dark anodized. Frame finish is as described in 2.02, A, 2 and at 2.06.
 - b. 2.04, C, 1: Change door thickness to 1 ¾ inches.

CHANGES TO DRAWINGS

2. At the head of all frames install a prefinished metal drip cap in color to match frames.

END OF DOCUMENT 00 90 00