

DOCUMENT 00 90 00
ADDENDUM

ADDENDUM NO. [1] Date: March 4, 2019

**RE: LACRESCENT-HOKAH PUBLIC SCHOOLS
HIGH SCHOOL PARTIAL REROOF
1301 LANCER BLVD
LA CRESCENT, MINNESOTA 55947
HSR 18068**

**FROM: HSR Associates, Inc
100 Milwaukee Street
La Crosse, WI 54603
(608) 784-1830**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated February 2019. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page and Pre-bid sign-in.

CHANGES TO BIDDING REQUIREMENTS AND CONDITIONS OF THE CONTRACT:

1. Pre-bid sign-in attached hereto

CHANGES TO SPECIFICATIONS

2. Section 07 31 13 ASPHALT SHINGLES
 - a. 2.01: Add the following approved shingle: Certaineed, Carriage House.

CHANGES TO DRAWINGS

3. Sheets A121 and A122 ROOF PLAN 'A' AND 'B'
 - a. Keynote 10: Remove existing smoke hatch. Raise hatch roof curb by minimum of 6 inches, flash and reinstall hatch and paint. Coordinate electrical and fire alarm disconnect/reconnect.
 - b. Keynote 12: At all roof top units/ mechanical equipment raise roof curb by minimum of 3 inches. Roofing contractor to contract directly with mechanical and electrical contractor for disconnect and reconnect HVAC equipment that is removed from curb. District has existing relationship with Advanced Comfort Specialists, LLC. Contact Tom Lee 608-783-2268.
 - c. Add keynote 12 to chiller location at Segment 'B'.

END OF DOCUMENT 00 90 00

Page Intentionally Left Blank

