

**DOCUMENT 00 90 00
ADDENDUM**

ADDENDUM NO. [4] Date: October 14, 2019

**RE: LANESBORO PUBLIC SCHOOLS
 ADDITION AND REMODEL REBID
 100 KIRKWOOD ST EAST
 LANESBORO, MN 55949
 HSR 18063**

**FROM: HSR Associates, Inc
 100 Milwaukee Street
 La Crosse, WI 54603
 (608) 784-1830**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated September 2019. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

CHANGES TO PREVIOUS ADDENDUM: Addendum 3

1. Item 14: Sheet E001 SITE PLAN – ELECTRICAL

- a. Revise Keynote 1 as follows: The Electric Utility shall provide the following: Transformer, concrete pad, vault and meter. The Electrical Contractor shall provide and install the following: conductors (copper or aluminum), raceways, meter installation and ct cabinet with pad. This work from the transformer to the building panel shall be coordinated and confirmed with the Electric Utility.

END OF DOCUMENT 00 90 00