

**DOCUMENT 00 90 00**  
**ADDENDUM**

**ADDENDUM NO. [1]**      **Date: August 14, 2020**

**RE:**            **VHA OFFICE RENOVATIONS**  
                 **PARK VIEW COURT**  
                 **200 PARK VIEW COURT**  
                 **VIROQUA, WISCONSIN 54665**  
                 **HSR PROJECT NO. 20030**

**FROM:**        HSR Associates, Inc  
                 100 Milwaukee Street  
                 La Crosse, WI 54603  
                 (608) 784-1830

**To:**    Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated July 2020. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

**CHANGES TO BIDDING REQUIREMENTS AND CONDITIONS OF THE CONTRACT:**

1. Section 00 22 13 SUPPLEMENTARY INSTRUCTIONS TO BIDDERS
  - a. 4.1.8: Delete paragraph .6. HUD form not required with bid.

**CHANGES TO SPECIFICATIONS:**

2. Section 08 43 13 ALUMINUM FRAMED STOREFRONT
  - a. 2.02, B: Add the following; "Fixed windows shall have a maximum .4 SHGC on the east side of the work area, and .53 on the north side."

**CHANGES TO DRAWINGS**

3. The title blocks on sheets A000, A100, A300, and M100 shall be revised to the following: "VHA Office Renovations" vs "VHA Office Reservations".
4. The work area in this project is considered a *Level* 2 per the 2015 IEBC and shall meet the requirements there-in of chapters 7 and 8.

**END OF DOCUMENT 00 90 00**