

**DOCUMENT 00 90 00  
ADDENDUM**

**ADDENDUM NO. [3]                      Date: October 30, 2020**

**RE:                      SOUTHWEST WISCONSIN TECHNICAL COLLEGE  
BUILDING 400 LECTURE HALL  
1800 BRONSON BLVD  
FENNIMORE, WI  
BID NUMBER: 2021-02**

**FROM:                HSR Associates, Inc  
100 Milwaukee Street  
La Crosse, WI 54603  
(608) 784-1830**

**To:     Prospective Bidders**

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated October 2020. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

**CHANGES TO DRAWINGS**

1. Sheet E200 POWER PLAN (No Drawing Reissued)
  - a. Electrical Room 102: Provide a 125 amp, 3 pole circuit breaker in existing 480 volt switchboard SWBD-1 with conduit and #2 awg to CU-2, match existing circuit breaker interrupting ratings. Electrical contractor to provide a Nema 3R, fused safety switch at new condensing unit CU-2, fuse at manufactures recommendations. Refer to sheet M101 for location.

**END OF DOCUMENT 00 90 00**