

**DOCUMENT 00 90 00**  
**ADDENDUM**

**ADDENDUM NO. [3]**                      **Date: January 5, 2021**

**RE:**                      **INDEPENDENCE SCHOOL DISTRICT**  
**EAST ELEMENTARY SCHOOL REMODEL**  
**1103 1<sup>ST</sup> ST W**  
**WEST ELEMENTARY SCHOOL ADDITION**  
**1301 1<sup>ST</sup> ST W**  
**INDEPENDENCE, IOWA 50644**  
**HSR PROJECT NO. 19045**

**FROM:**                HSR Associates, Inc  
100 Milwaukee Street  
La Crosse, WI 54603  
(608) 784-1830

**To:**    Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated December 2020. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [2] pages.

**CHANGES TO SPECIFICATIONS:**

1. Section 23 09 23 Direct Digital Control System for HVAC
  - a. The contact for the existing HVAC controls is:  
Existing Easy IO Control System  
Brett Landsdown  
(319)360-4273

**CHANGES TO DRAWINGS:**

2. West Elementary: Sheet A120 ROOF PLAN No Drawing Reissued
  - a. Change Roof Description A to the following:  
Adhered single membrane roofing system over 5.5 inches of polyisocyanurate insulation with crickets as shown on Drawing. Average R-value-30. Install manufacturer's vapor barrier as specified in 07 53 00. Overlap and seal perimeter.

**PRIOR APPROVALS**

1. Section 23 09 14 Electric Instrumentation and Control Devices for HVAC: 2.10\_Thermal Dispersion Airflow Station
  - a. Ruskin
2. Section 23 74 13 Packaged Gas/Electric Rooftop Units: 2.01
  - a. Daikin
3. Section 23 82 01 Hydronic Terminal Units: 2.03 Unit Heaters
  - a. Daikin

4. Section 23 82 16 Duct Coils: 2.02 Hot Water Heating Coils
  - a. Temtrol
5. Section 26 51 00 Interior Lighting
  - a. Hubbell Lighting
  - b. Cooper Lighting

**END OF DOCUMENT 00 90 00**