

**DOCUMENT 00 90 00  
ADDENDUM**

**ADDENDUM NO. [1]                      Date: October 22, 2021**

**RE:                      INDEPENDENCE COMMUNITY SCHOOL DISTRICT  
WEST ELEMENTARY & JUNIOR/SENIOR HIGH SCHOOL HVAC UPGRADES  
INDEPENDENCE, IOWA 50644  
HSR PROJECT NO. 21014**

**FROM:                  HSR Associates, Inc.  
100 Milwaukee Street  
La Crosse, WI 54603  
(608) 784-1830**

**To:                      Prospective Bidders**

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated September 2021. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page.

**CHANGES TO SPECIFICATIONS:**

1. Section 23 40 00 Air Purification Systems
  - a. Paragraph 2.03 Ion Generators
    - i. Subparagraph 2. Air Handler mounted units:
      1. Item g
        - a. Remove ion sensor with BMS interface.
  - b. Clarification Item: All ion generators shall be standalone operation. No building automation interface will be done as a part of the project.

**END OF DOCUMENT 00 90 00**