

**DOCUMENT 00 90 00
ADDENDUM**

ADDENDUM NO. [1] Date: December 14, 2021

**RE: SCHOOL DISTRICT OF HOLMEN
MIDDLE SCHOOL & VIKING ELEMENTARY HVAC UPGRADES
502 NORTH MAIN STREET & 500 EAST WALL STREET
HOLMEN, WI 54636**

**FROM: HSR Associates, Inc.
100 Milwaukee Street
La Crosse, WI 54603
(608) 784-1830**

To: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated December 2021. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of [1] page, [1] Revised Bid Form.

CHANGES TO BIDDING REQUIREMENTS AND CONDITIONS OF THE CONTRACT:

1. Pre-bid attendance attached hereto.

CHANGES TO SPECIFICATIONS:

2. Section 23 05 13 MOTORS AND VARIABLE FREQUENCY DRIVES
 - a. Clarification: VFD's shall be provided in bid by mechanical contractor and installed by electrical contractor. Control contractor (by owner) will provide low voltage wiring.

CHANGES TO DRAWINGS

3. Sheet M100 MIDDLE SCHOOL PIPING PLANS (No Drawing Reissued)
 - a. Contractor shall remove all refrigerant piping and accessories from removed condensing unit to removed air handling unit and dispose refrigerant.
 - b. Owner to provide double door installation to gain access into Library space for AHU replacement.

PRIOR APPROVALS

1. Section 23 21 15 CHILLED AND CONDENSER WATER SYSTEMS
 - a. Ethylene Glycol
 - i. Compatibility of new and existing glycol shall be confirmed prior to installation.
 - ii. Fremont
 - iii. Rhomar Water

END OF DOCUMENT 00 90 00

Page Intentionally Left Blank

Page Intentionally Left Blank