

DOCUMENT 00 90 00
ADDENDUM

ADDENDUM No.: 4

DATE: March 13, 2023

RE: NORTHWOOD TECHNICAL COLLEGE
RICE LAKE OFFICE RENOVATION
1900 COLLEGE DERIVE
RICE LAKE, WISCONSIN 54868
PROJECT NO. 22039

FROM: HSR Associates, Inc
100 Milwaukee Street
La Crosse, WI 54603
(608) 784-1830

TO: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated February 2023. Acknowledge receipt of this Addendum in the space provided on the bid form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of: 1 page, 0 documents, 0 sections, and 0 drawings.

1. Section 09 51 00 Acoustical Ceilings
 - a. See the narrative, immediately below, describing revisions to the section.
 - b. In paragraph 2.02 B.1. Acoustical Units; Replace "Armstrong: Optima" with "Armstrong: Ultima".
 - c. Add new paragraph 2.02 C.1. "Minimum NRC: 75"

END OF DOCUMENT 00 90 00